

臺北市立中山國小 飲水機設備維護紀錄表

維護日期: 03 年 12 月 1 日

設備負責人：總務處事務組

水源類別：自來水

登記使用有效期間:109年12月31日

連絡電話: 28322200

設備管理人:陳小姐

序 列	位 置	單 位 名 稱	設備維護(每月)					更換濾心		消毒	其他	備註
			檢查按鍵 及功能是否 正查	檢測漏電 斷路器是否 會正常跳脫	檢查壓縮 機及風扇 啟動狀況	查看排水 是否通暢 及是否有 漏水	填寫維護 紀錄卡及 紀錄是否 完整	更換纖維 濾心 (3.6.9.1 2月)	更換碳柄 濾心 (3.6.9.1 2月)			
1	大智樓1樓	A102	✓	✓	✓	✓	✓	✓	✓			
2	大智樓1樓	A103	✓	✓	✓	✓	✓	✓	✓			
3	大智樓1樓	A105	✓	✓	✓	✓	✓	✓	✓			
4	大智樓1樓	A107	✓	✓	✓	✓	✓					新機
5	大智樓2樓	A202	✓	✓	✓	✓	✓	✓	✓			
6	大智樓2樓	A204	✓	✓	✓	✓	✓	✓	✓			
7	大智樓3樓	A302	✓	✓	✓	✓	✓	✓	✓			
8	大智樓3樓	A307	✓	✓	✓	✓	✓	✓	✓			
9	大仁樓1樓	B102	✓	✓	✓	✓	✓	✓	✓			
10	大仁樓1樓	B104	✓	✓	✓	✓	✓	✓	✓			
11	大仁樓1樓	B108	✓	✓	✓	✓	✓	✓	✓			
12	大仁樓2樓	B201	✓	✓	✓	✓	✓	✓	✓			
13	大仁樓2樓	B204	✓	✓	✓	✓	✓	✓	✓			
14	大仁樓2樓	B206	✓	✓	✓	✓	✓	✓	✓			
15	大仁樓3樓	B301	✓	✓	✓	✓	✓	✓	✓			
16	大仁樓3樓	B304	✓	✓	✓	✓	✓	✓	✓			
17	大仁樓3樓	B308	✓	✓	✓	✓	✓	✓	✓			
18	大勇樓1樓	C106	✓	✓	✓	✓	✓	✓	✓			
19	大勇樓1樓	C102	✓	✓	✓	✓	✓	✓	✓			
20	大勇樓2樓	C205	✓	✓	✓	✓	✓	✓	✓			
21	大勇樓2樓	C203	✓	✓	✓	✓	✓	✓	✓			
22	大勇樓3樓	C308	✓	✓	✓	✓	✓	✓	✓			
23	大勇樓3樓	C305	✓	✓	✓	✓	✓	✓	✓			
24	大勇樓3樓	C303	✓	✓	✓	✓	✓	✓	✓			
25	明道1樓	D101	✓	✓	✓	✓	✓	✓	✓			
26	明道1樓	D104	✓	✓	✓	✓	✓	✓	✓			
27	明道2樓	D201	✓	✓	✓	✓	✓	✓	✓			
28	明道2樓	D204	✓	✓	✓	✓	✓	✓	✓			
29	明道3樓	D301	✓	✓	✓	✓	✓	✓	✓			
30	明道3樓	D304	✓	✓	✓	✓	✓	✓	✓			
31	活動中心	1F	✓	✓	✓	✓	✓	✓	✓			
32	活動中心	2F	✓	✓	✓	✓	✓	✓	✓			
33	活動中心	3F	✓	✓	✓	✓	✓	✓	✓			
34	正誼1樓	E101	✓	✓	✓	✓	✓					新機

臺北市立中山國小 飲水機設備維護紀錄表

維護日期: 109 年 12 月 7 日
 設備負責人: 總務處事務組
 水源類別: 自來水

登記使用有效期間: 109年12月31日
 連絡電話: 28322200
 設備管理人: 陳小姐

序 列	位 置	單 位 名 稱	設備維護(每月)					更換濾心		消毒	其他	備 註
			檢查按鍵 及功能是 否正查	檢測漏電 斷路器是 否會正常 跳脫	檢查壓縮 機及風扇 啟動狀況	查看排水 是否通暢 及是否有 漏水	填寫維護 紀錄卡及 紀錄是否 完整	更換纖維 濾心 (3.6.9.1 2月)	更換碳柄 濾心 (3.6.9.1 2月)			
35	自強1樓	E108	✓	✓	✓	✓	✓					新机
36	自強1樓	E112	✓	✓	✓	✓	✓					新机
37	自強2樓	E204	✓	✓	✓	✓	✓	✓	✓			
38	自強2樓	E208	✓	✓	✓	✓	✓	✓	✓			
39	自強2樓	E212	✓	✓	✓	✓	✓	✓	✓			
40	自強3樓	E304	✓	✓	✓	✓	✓	✓	✓			
41	自強3樓	E308	✓	✓	✓	✓	✓	✓	✓			
42	自強3樓	E312	✓	✓	✓	✓	✓	✓	✓			
43	自強4樓	E404	✓	✓	✓	✓	✓	✓	✓			
44	自強4樓	E408	✓	✓	✓	✓	✓	✓	✓			
45	自強4樓	E411	✓	✓	✓	✓	✓	✓	✓			
46	大智樓1樓	A104	✓	✓	✓	✓	✓					新机
47	幼稚園廚房		✓	✓	✓	✓	✓	✓	✓			
開-1	幼稚園廚房		✓	✓	✓	✓	✓	✓	✓			

設備維護單位: 力霸工業科技(股)公司

電話: 02-2832-2200

維護人員簽章:

吳啟智

設備負責人簽名:

林慧音