

臺北市立中山國小 飲水機設備維護紀錄表

維護日期: 106 年 1 月 10 日

設備負責人: 總務處事務組

水源類別: 自來水

登記使用有效期間: 109年12月31日

連絡電話: 28322200

設備管理人: 陳小姐

序 列	位 置	單 位 名 稱	設備維護(每月)					更換濾心		消毒	其他	備註
			檢查按鈕 及功能是否 正常	檢測漏電 斷路器是否 會正常跳脫	檢查壓縮 機及風扇 啟動狀況	查看排水 是否通暢 及是否有 漏水	填寫維護 紀錄卡及 紀錄是否 完整	更換纖維 濾心 (3.6.9.1 2月)	更換碳柄 濾心 (3.6.9.1 2月)			
1	大智樓1樓	A102	✓	✓	✓	✓	✓					
2	大智樓1樓	A103	✓	✓	✓	✓	✓					
3	大智樓1樓	A105	✓	✓	✓	✓	✓					
4	大智樓1樓	A107	✓	✓	✓	✓	✓					
5	大智樓2樓	A202	✓	✓	✓	✓	✓					
6	大智樓2樓	A204	✓	✓	✓	✓	✓					
7	大智樓3樓	A302	✓	✓	✓	✓	✓					
8	大智樓3樓	A307	✓	✓	✓	✓	✓					
9	大仁樓1樓	B102	✓	✓	✓	✓	✓					
10	大仁樓1樓	B104	✓	✓	✓	✓	✓					
11	大仁樓1樓	B108	✓	✓	✓	✓	✓					
12	大仁樓2樓	B201	✓	✓	✓	✓	✓					
13	大仁樓2樓	B204	✓	✓	✓	✓	✓					
14	大仁樓2樓	B206	✓	✓	✓	✓	✓					
15	大仁樓3樓	B301	✓	✓	✓	✓	✓					
16	大仁樓3樓	B304	✓	✓	✓	✓	✓					
17	大仁樓3樓	B308	✓	✓	✓	✓	✓					
18	大勇樓1樓	C106	✓	✓	✓	✓	✓					
19	大勇樓1樓	C102	✓	✓	✓	✓	✓					
20	大勇樓2樓	C205	✓	✓	✓	✓	✓					
21	大勇樓2樓	C203	✓	✓	✓	✓	✓					
22	大勇樓3樓	C308	✓	✓	✓	✓	✓					
23	大勇樓3樓	C305	✓	✓	✓	✓	✓					
24	大勇樓3樓	C303	✓	✓	✓	✓	✓					
25	明道1樓	D101	✓	✓	✓	✓	✓					
26	明道1樓	D104	✓	✓	✓	✓	✓					
27	明道2樓	D201	✓	✓	✓	✓	✓					
28	明道2樓	D204	✓	✓	✓	✓	✓					
29	明道3樓	D301	✓	✓	✓	✓	✓					
30	明道3樓	D304	✓	✓	✓	✓	✓					
31	活動中心	1F	✓	✓	✓	✓	✓					
32	活動中心	2F	✓	✓	✓	✓	✓					
33	活動中心	3F	✓	✓	✓	✓	✓					

臺北市立中山國小 飲水機設備維護紀錄表

維護日期: 106年 1 月 10日
 設備負責人: 總務處事務組
 水源類別: 自來水

登記使用有效期間: 109年12月31日
 連絡電話: 28322200
 設備管理人: 陳小姐

序 列	位 置	單 位 名 稱	設備維護(每月)					更換濾心		消毒	其他	備註
			檢查按鍵 及功能是否正查	檢測漏電 斷路器是否會正常 跳脫	檢查壓縮 機及風扇 啟動狀況	查看排水 是否通暢 及是否有 漏水	填寫維護 紀錄卡及 紀錄是否 完整	更換纖維 濾心 (3.6.9.1 2月)	更換碳柄 濾心 (3.6.9.1 2月)			
34	正誼1樓	E101	✓	✓	✓	✓	✓					
35	自強1樓	E108	✓	✓	✓	✓	✓					
36	自強1樓	E112	✓	✓	✓	✓	✓					
37	自強2樓	E204	✓	✓	✓	✓	✓					
38	自強2樓	E208	✓	✓	✓	✓	✓					
39	自強2樓	E212	✓	✓	✓	✓	✓					
40	自強3樓	E304	✓	✓	✓	✓	✓					
41	自強3樓	E308	✓	✓	✓	✓	✓					
42	自強3樓	E312	✓	✓	✓	✓	✓					
43	自強4樓	E404	✓	✓	✓	✓	✓					
44	自強4樓	E408	✓	✓	✓	✓	✓					
45	自強4樓	E411	✓	✓	✓	✓	✓					
46	大智樓1樓	A104	✓	✓	✓	✓	✓					
47	幼稚園廚房						✓					
開-1	幼稚園廚房		✓	✓		✓	✓					

設備維護單位: 力霸工業科技(股)公司

電話: 02-2832-2200

維護人員簽章:



設備負責人簽名:



臺北市立中山國小 飲水機設備維護紀錄表

維護日期: 106 年 2 月 17 日

設備負責人: 總務處事務組

水源類別: 自來水

登記使用有效期間: 109年12月31日

連絡電話: 28322200

設備管理人: 陳小姐

序 列	位 置	單 位 名 稱	設備維護(每月)					更換濾心		消毒	其他	備註
			檢查按鍵 及功能是 否正查	檢測漏電 斷路器是 否會正常 跳脫	檢查壓縮 機及風扇 啟動狀況	查看排水 是否通暢 及是否有 漏水	填寫維護 紀錄卡及 紀錄是否 完整	更換纖維 濾心 (3.6.9.1 2月)	更換碳柄 濾心 (3.6.9.1 2月)			
1	大智樓1樓	A102	✓	✓	✓	✓	✓					
2	大智樓1樓	A103	✓	✓	✓	✓	✓					
3	大智樓1樓	A105	✓	✓	✓	✓	✓					
4	大智樓1樓	A107	✓	✓	✓	✓	✓					
5	大智樓2樓	A202	✓	✓	✓	✓	✓					
6	大智樓2樓	A204	✓	✓	✓	✓	✓					
7	大智樓3樓	A302	✓	✓	✓	✓	✓					
8	大智樓3樓	A307	✓	✓	✓	✓	✓					
9	大仁樓1樓	B102	✓	✓	✓	✓	✓					
10	大仁樓1樓	B104	✓	✓	✓	✓	✓					
11	大仁樓1樓	B108	✓	✓	✓	✓	✓					
12	大仁樓2樓	B201	✓	✓	✓	✓	✓					
13	大仁樓2樓	B204	✓	✓	✓	✓	✓					
14	大仁樓2樓	B206	✓	✓	✓	✓	✓					
15	大仁樓3樓	B301	✓	✓	✓	✓	✓					
16	大仁樓3樓	B304	✓	✓	✓	✓	✓					
17	大仁樓3樓	B308	✓	✓	✓	✓	✓					
18	大勇樓1樓	C106	✓	✓	✓	✓	✓					
19	大勇樓1樓	C102	✓	✓	✓	✓	✓					
20	大勇樓2樓	C205	✓	✓	✓	✓	✓					
21	大勇樓2樓	C203	✓	✓	✓	✓	✓					
22	大勇樓3樓	C308	✓	✓	✓	✓	✓					
23	大勇樓3樓	C305	✓	✓	✓	✓	✓					
24	大勇樓3樓	C303	✓	✓	✓	✓	✓					
25	明道1樓	D101	✓	✓	✓	✓	✓					
26	明道1樓	D104	✓	✓	✓	✓	✓					
27	明道2樓	D201	✓	✓	✓	✓	✓					
28	明道2樓	D204	✓	✓	✓	✓	✓					
29	明道3樓	D301	✓	✓	✓	✓	✓					
30	明道3樓	D304	✓	✓	✓	✓	✓					
31	活動中心	1F	✓	✓	✓	✓	✓					
32	活動中心	2F	✓	✓	✓	✓	✓					
33	活動中心	3F	✓	✓	✓	✓	✓					
34	正誼1樓	E101	✓	✓	✓	✓	✓					

臺北市立中山國小 飲水機設備維護紀錄表

維護日期: 106年2月10日

設備負責人: 總務處事務組

水源類別: 自來水

登記使用有效期間: 109年12月31日

連絡電話: 28322200

設備管理人: 陳小姐

序 列	位 置	單 位 名 稱	設備維護(每月)					更換濾心		消毒	其他	備註
			檢查按鍵 及功能是 否正查	檢測漏電 斷路器是 否會正常 跳脫	檢查壓縮 機及風扇 啟動狀況	查看排水 是否通暢 及是否有 漏水	填寫維護 紀錄卡及 紀錄是否 完整	更換纖維 濾心 (3.6.9.1 2月)	更換碳柄 濾心 (3.6.9.1 2月)			
35	自強1樓	E108	✓	✓	✓	✓	✓					
36	自強1樓	E112	✓	✓	✓	✓	✓					
37	自強2樓	E204	✓	✓	✓	✓	✓					
38	自強2樓	E208	✓	✓	✓	✓	✓					
39	自強2樓	E212	✓	✓	✓	✓	✓					
40	自強3樓	E304	✓	✓	✓	✓	✓					
41	自強3樓	E308	✓	✓	✓	✓	✓					
42	自強3樓	E312	✓	✓	✓	✓	✓					
43	自強4樓	E404	✓	✓	✓	✓	✓					
44	自強4樓	E408	✓	✓	✓	✓	✓					
45	自強4樓	E411	✓	✓	✓	✓	✓					
46	大智樓1樓	A104	✓	✓	✓	✓	✓					
47	幼稚園廚房		✓	✓	✓	✓	✓					
開-1	幼稚園廚房		✓	✓	✓	✓	✓					

設備維護單位: 力霸工業科技(股)公司

電話: 02-2832-2200

維護人員簽章: 

設備負責人簽名:



臺北市立中山國小 飲水機設備維護紀錄表

維護日期: 104年3月1日

設備負責人: 總務處事務組

水源類別: 自來水

登記使用有效期間: 109年12月31日

連絡電話: 28322200

設備管理人: 陳小姐

序 列	位 置	單 位 名 稱	設備維護(每月)					更換濾心		消毒	其他	備註	廠牌
			檢查按鈕 及功能是否正查	檢測漏電 斷路器是否會正常 跳脫	檢查壓縮 機及風扇 啟動狀況	查看排水 是否通暢 及是否有 漏水	填寫維護 紀錄卡及 紀錄是否 完整	更換纖維 濾心 (3.6.9.1 2月)	更換碳柄 濾心 (3.6.9.1 2月)				
1	大智樓1樓	A102	✓	✓	✓	✓	✓	✓	✓				力霸
2	大智樓1樓	A103	✓	✓	✓	✓	✓	✓	✓				力霸
3	大智樓1樓	A105	✓	✓	✓	✓	✓	✓	✓				力霸
4	大智樓1樓	A107	✓	✓	✓	✓	✓	✓	✓				力霸
5	大智樓2樓	A202	✓	✓	✓	✓	✓	✓	✓	✓			賀眾
6	大智樓2樓	A204	✓	✓	✓	✓	✓	✓	✓	✓			力霸
7	大智樓3樓	A302	✓	✓	✓	✓	✓	✓	✓				賀眾
8	大智樓3樓	A307	✓	✓	✓	✓	✓	✓	✓				賀眾
9	大仁樓1樓	B102	✓	✓	✓	✓	✓	✓	✓				力霸
10	大仁樓1樓	B104	✓	✓	✓	✓	✓	✓	✓				力霸
11	大仁樓1樓	B108	✓	✓	✓	✓	✓	✓	✓				力霸
12	大仁樓2樓	B201	✓	✓	✓	✓	✓	✓	✓				力霸
13	大仁樓2樓	B204	✓	✓	✓	✓	✓	✓	✓				賀眾
14	大仁樓2樓	B206	✓	✓	✓	✓	✓	✓	✓				力霸
15	大仁樓3樓	B301	✓	✓	✓	✓	✓	✓	✓				賀眾
16	大仁樓3樓	B304	✓	✓	✓	✓	✓	✓	✓				力霸
17	大仁樓3樓	B308	✓	✓	✓	✓	✓	✓	✓				賀眾
18	大勇樓1樓	C106	✓	✓	✓	✓	✓	✓	✓				力霸
19	大勇樓1樓	C102	✓	✓	✓	✓	✓	✓	✓				力霸
20	大勇樓2樓	C205	✓	✓	✓	✓	✓	✓	✓				力霸
21	大勇樓2樓	C203	✓	✓	✓	✓	✓	✓	✓				賀眾
22	大勇樓3樓	C308	✓	✓	✓	✓	✓	✓	✓				力霸
23	大勇樓3樓	C305	✓	✓	✓	✓	✓	✓	✓				力霸
24	大勇樓3樓	C303	✓	✓	✓	✓	✓	✓	✓				賀眾
25	明道1樓	D101	✓	✓	✓	✓	✓	✓	✓				力霸
26	明道1樓	D104	✓	✓	✓	✓	✓	✓	✓				力霸
27	明道2樓	D201	✓	✓	✓	✓	✓	✓	✓				賀眾
28	明道2樓	D204	✓	✓	✓	✓	✓	✓	✓				賀眾
29	明道3樓	D301	✓	✓	✓	✓	✓	✓	✓				賀眾
30	明道3樓	D304	✓	✓	✓	✓	✓	✓	✓				力霸
31	活動中心	1F	✓	✓	✓	✓	✓	✓	✓				力霸
32	活動中心	2F	✓	✓	✓	✓	✓	✓	✓				力霸
33	活動中心	3F	✓	✓	✓	✓	✓	✓	✓				力霸
34	正誼1樓	E101	✓	✓	✓	✓	✓	✓	✓				力霸

臺北市立中山國小 飲水機設備維護紀錄表

維護日期: 106 年 3 月 1 日
 設備負責人: 總務處事務組
 水源類別: 自來水

登記使用有效期間: 109年12月31日
 連絡電話: 28322200
 設備管理人: 陳小姐

序 列	位 置	單 位 名 稱	設備維護(每月)					更換濾心		消毒	其他	備註	廠牌
			檢查按鈕 及功能是否正查	檢測漏電 斷路器是否會正常 跳脫	檢查壓縮 機及風扇 啟動狀況	查看排水 是否通暢 及是否有 漏水	填寫維護 紀錄卡及 紀錄是否 完整	更換纖維 濾心 (3.6.9.1 2月)	更換碳柄 濾心 (3.6.9.1 2月)				
35	自強1樓	E108	✓	✓	✓	✓	✓	✓	✓				力霸
36	自強1樓	E112	✓	✓	✓	✓	✓	✓	✓				力霸
37	自強2樓	E204	✓	✓	✓	✓	✓	✓	✓				賀眾
38	自強2樓	E208	✓	✓	✓	✓	✓	✓	✓				力霸
39	自強2樓	E212	✓	✓	✓	✓	✓	✓	✓				力霸
40	自強3樓	E304	✓	✓	✓	✓	✓	✓	✓				賀眾
41	自強3樓	E308	✓	✓	✓	✓	✓	✓	✓				賀眾
42	自強3樓	E312	✓	✓	✓	✓	✓	✓	✓				賀眾
43	自強4樓	E404	✓	✓	✓	✓	✓	✓	✓				賀眾
44	自強4樓	E408	✓	✓	✓	✓	✓	✓	✓				賀眾
45	自強4樓	E411	✓	✓	✓	✓	✓	✓	✓				賀眾
46	大智樓1樓	A104	✓	✓	✓	✓	✓	✓	✓				賀眾
47	幼稚園廚房		✓	✓	✓	✓	✓	✓	✓				力霸
開-1	幼稚園廚房		✓	✓	✓	✓	✓	✓	✓				賀眾

設備維護單位: 力霸工業科技(股)公司

電話: 02-2832-2200

維護人員簽章: 

設備負責人簽名: 